

Maintenance



Service Order 000773380751
Contract Number 42098513
Customer Name AFNO CGHS LTD

Site Name AFNO CGHS LTD
Equipment Number 43203157
Equipment ID -
Address PLOT NO-11, SECTOR-7, DWARKA,
City DELHI
Post Code 110075

Job Description Routine maintenance completed, back to normal

Attended By Laxman KUMAR

Arrived Time 21/11/2022 11:05:29

Work Completed Time 21/11/2022 12:35:32

Maintenance modules performed

- Y: Basic inspection
- D: Door operator module
- L: Landing door module

This is a record of completion for the above maintenance modules. Should there be any items that we need to bring to your attention, following this visit a member of our team will be in contact.

Comments Customer

1. Water Found in pit need to be waterproofing properly
2. Cwt guide rail buffer and tention weight found rusted due tp water damage
3. Some of the shaft lights not working - Replaced
4. ERD Not Working Battery Required - Procurement to be initiated
5. Machine Room white wash need

(Light No. 11)
Block No. 3B

Customer Signature

Secretary
Authorized Signatory

Work to be initiated

Signed By

This e-mail is generated automatically.

NOTICE: The information contained in this message or files attached to it are intended for the exclusive use of the addressee and may contain confidential or legally privileged information. If you are not the intended recipient, please note that the use, copying, any form of dissemination and any other corresponding action in respect of this communication is strictly prohibited. If you received this message in error, please delete the message and notify the sender immediately. Thank you. Please note that we take reasonable precautions to prevent the transmission of viruses; however, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not be liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt Ltd, . . . DELHI, 110034
Tel No: +91 11 47008622, Fax: , www.kone.com,

(OP Govil) :
Wg Cdr (Retd.)
Vice President
AFNO CGHS Ltd.



Maintenance

Service Order

00077369032

Contract Number

42098513

Customer Name

AFNO CGHS LTD

Site Name

AFNO CGHS LTD

Equipment Number

43203152

Equipment ID

-

Address

PLOT NO-11, SECTOR-7,DWARKA,

City

DELHI

Post Code

110075

Job Description

Routine maintenance completed, back to normal

Attended By

SANDEEP KUMAR

Arrived Time

21/11/2022 09:13:33

Work Completed Time

21/11/2022 10:21:39

Maintenance modules performed

B: Basic module

(Lift No. 4)
Block-1B

This is a record of completion for the above maintenance modules. Should there be any items that we need to bring to your attention, following this visit a member of our team will be in contact.

Comments Customer

Customer Signature


Secretary
~~Authorized Signatory~~

Signed By



(OP Govt.)
Wg Cdr (Retd.)
Vice President
AFNO CGHS Ltd.

This e-mail is generated automatically.

NOTICE: The information contained in this message or files attached to it are intended for the exclusive use of the addressee and may contain confidential or proprietary information. If you are not the intended recipient, please note that the use, copying, any disclosure, distribution and any other corresponding activity in respect of this communication is strictly prohibited. If you received this message in error, please delete the message and notify the sender immediately. Thank you. Please note that we take reasonable precautions to prevent the transmission of viruses, however, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not be liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt.Ltd. . . . DELHI, 110034
Tel.No: +91 11 47008022, Fax: . . . www.kone.com,

Maintenance



Service Order 000773352760
Contract Number 42098513
Customer Name AFNO CGHS LTD
Site Name AFNO CGHS LTD
Equipment Number 43203147
Address PLOT NO-11, SECTOR-7,DWARKA,
City DELHI
Post Code 110075

Job Description Routine maintenance completed, back to normal
Attended By Laxman KUMAR
Arrived Time 21/11/2022 13:13:32
Work Completed Time 21/11/2022 14:45:03
Maintenance modules performed Y: Basic inspection
D: Door operator module
L: Landing door module
This is a record of completion for the above maintenance modules. Should there be any items that we need to bring to your attention, following this visit a member of our team will be in contact.
Comments Customer 1. Some of the Shaft light not working
2. Etd Not working Battery Required
Recommendation to be taken today

Customer Signature

Signed By

This e-mail is generated automatically.

NOTICE: The information contained in this message or files attached to it are intended for the addressee and may contain confidential or legally privileged information. If you are not the intended recipient, please note that the use, copying, any form of dissemination and any other corresponding action in re. Please note that we take reasonable precautions to prevent the transmission of viruses; however, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not be liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt.Ltd. . . . DELHI, 110034
Tel No: +91 11 47008622, Fax: . www.kone.com.

Secretary

(OP GOVIL)
W/g Cdr (Retd)
Vice President
AFNO CGHS Ltd

Maintenance



Service Order
Contract Number
Customer Name

000773380752
42098513
AFNO CGHS LTD

Site Name

AFNO CGHS LTD

Equipment Number
Equipment ID

43203159

Address

City

Post Code

PLOT NO-11, SECTOR-7, DWARKA,

DELHI

110075

Job Description

Attended By

Routine maintenance completed, back to normal
Laxman KUMAR

Arrived Time

22/11/2022 11:25:06

Work Completed Time

22/11/2022 13:00:05

Maintenance modules performed

Y: Basic inspection
D: Door operator module
L: Landing door module

(Lift No. 15
Block No. 4B)

This is a record of completion for the above maintenance modules. Should there be any items that we need to bring to your attention, following this visit a member of our team will be in contact.

Comments Customer

- 1. Some of the Shaft light not working
- 2. End not working battery required

Customer Signature

Preparation of batteries is to be initiated
(Laxman) 22-11-22

Signed By

(Signature)
22.11.22
Secretary

This e-mail is generated automatically.
NOTICE: The information contained in this message or files attached to it are intended for the exclusive use of the addressee and may contain confidential or legally privileged information. If you are not the intended recipient, please note that the use, copying or distribution of this information is strictly prohibited. If you have received this message in error, please delete the message and notify the sender immediately. Thank you. Please note that we take reasonable precautions to protect the confidentiality of our e-mail messages. However, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt.Ltd., DELHI, 110034
Tel No: +91 11 47008622, Fax: , www.kone.com,

(OP Govil)
Mg Cdr (Retd.)
Vice President
AFNO CGHS Ltd.

(Signature)



Callout

Status Shutdown

Dispatch number 9AIN11886704
 Caller Name / Time MR. SANJAY DOGRA On 23/11/2022 19:48:49
 MR. SANJAY DOGRA
 BreakDown - Lift Not working

Customer Name AFNO CGHS LTD
 Site Name AFNO CGHS LTD
 Equipment Type Elevator
 Equipment Number 43203143
 Equipment ID -
 Street PLOT NO-11, SECTOR-7,DWARKA,
 City DELHI
 Post Code 110075
 Fitter Name Pradeep DABAS
 Arrived Time 23/11/2022 20:26:01
 Work Completed Time 23/11/2022 21:12:05

Equipment Condition on Arrival Not running - At floor - door closed
 Job Description drive not working need to be checked.
 Action Description Repaired *be*
 Reason Description Technical failure
 Equipment Condition on Leaving 03 Equipment not running or will still be out of order
 Customer Comments

Customer Signature *[Signature]* Equipment is on maintenance
 Signed By *[Signature]* 24-11-22 Secretary No Signature Available *SHUT DOWN*

This e-mail is generated automatically.
 NOTE: The information contained in this message or files attached to it are intended for the exclusive use of the addressee and may contain confidential or legally privileged information. If you are not the intended recipient, please note that the use, copying, any form of dissemination and any other corresponding action in respect of this communication is strictly prohibited. If you received this message in error, please delete the message and notify the sender immediately. Your presence note that we take reasonable precautions to prevent the transmission of viruses, however, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not be liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt Ltd. . . . DELHI, 110034
 Tel No: +91 11 47008622, Fax: . www.kone.com.
[Signature]
 (Mr. Govil)
 Vign Cdr (Retd.)
 Vice President
 AFNO CGHS Ltd.

Callout



Status Closed

Dispatch number
Caller Name / Time

9AIN11886704

MR. SANJAY DOGRA
MR. SANJAY DOGRA

On 23/11/2022 19:48:49

Failure Description

Breakdown - Lift Not working

Customer Name

AFNO CGHS LTD

Site Name

AFNO CGHS LTD

Equipment Type

Elevator

Equipment Number

43203143

Equipment ID

Street

PLOT NO-11, SECTOR-7, DWARKA,

City

DELHI

Post Code

110075

Fitter Name

Laxman KUMAR
Mohit KUMAR
Pradeep DABAS

(LIFT No. 5)
Block 2 (A)

Arrived Time

23/11/2022 20:26:01

Work Completed Time

24/11/2022 17:53:43

Equipment Condition on Arrival

Not running - AI floor - door closed

Job Description

lift was shutdown due to opn having fault 106 of drive
so kdt16s 12amp drive replaced now and lift is working
good now

Repaired

Technical failure

Action Description

Reason Description


Equipment Condition on Leaving

01 Equipment running, back to normal operation

Customer Comments

Customer Signature

Signed By


Secretary
24.11.22

Secretary

This e-mail is generated automatically.

NOTE: The information contained in this message or files attached to it are intended for the addressee and may contain confidential or legally privileged information. If you are not the intended recipient, please note that the use, copying, any form of dissemination and any other corresponding action in respect of this communication is strictly prohibited. If you receive this message in error, please delete the message and notify the sender immediately. Thank you. Please note that we take reasonable precautions to prevent the transmission of viruses, however, we cannot guarantee that this message or its attachments are free from viruses. We only send and receive emails on the basis that we are not be liable for any loss or damage resulting from the opening of this message and/or attachments.

KONE Elevator India Pvt.Ltd., . . . DELHI, 110034
Tel.No: +91 11 47008622, Fax: . www.kone.com.

(OP Govil)
Wg Cdr (Retd.)
Vice President
AFNO CGHS Ltd.